

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-1483:108 Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Brad Miller (888) 649-9827

DESIGN: Models 75313U, 75316U, 75317U, 75320U, 75321U, 75322U, 75323U, 75324U, 75325U and 75326U door holders. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire-rated door holders. When used on fire-rated doors an approved closer shall be used.

XLF: 3550-1388:100

03-26-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2001

*Listing Expires **June 30, 2002***

Authorized By:

BEN HO, Supervising Deputy
Program Manager